

Part 3

Subject: Control and Instrumentation (ENV tested)

Product: Transmitted (Part 3)

Producer/Licence No.	Description of Product				Cert. No.
	Type	Details of Approval	Application	Remarks	
PSM Instrumentation Ltd., Unit 3, Burrell Road, Haywards Heath, West Sussex RH16 1TW United Kingdom	Intelligent Measurement Transmitter - ICT 1000 Termination and Barrier Module - RFM	Power Supply Voltage: ICT 1000 : 8 - 30 V DC RFM : 15 - 35 V DC Ingress Protection: ICT 1000 : IP 68 RFM : IP 67 <u>OTHER CONDITIONS:</u> The installation is to be carried out in accordance with the manufacturer's fitting instruction and applicable Rules and Regulations when installed on LR classed vessels.	For use in environmental categories ENV1, ENV2, ENV3 and ENV5 as defined in LR Test Specification No. 1: 2013.	Expires: 29 September 2020 Complies with: LR Rules and Regulations for the Classification of Ships, 2014, LR Test Spec No.1 2013	09/00011(E1)

