

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Level Switches**with type designation(s)
KD-12, KD-30, KD-90

Issued to

**Kuk Dong Level Co.
Busan, Republic of Korea**

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.**

Temperature	B
Humidity	A
Vibration	A
EMC	NA
Enclosure	Required protection according to DNV GL Rules shall be provided upon installation on board

Issued at **Busan** on **2020-07-28**for **DNV GL**This Certificate is valid until **2025-05-25**.DNV GL local station: **Gimhae Station**Approval Engineer: **Eun Sook Kim**

**Andreas Kristoffersen
Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Job Id: **262.1-033987-1**
Certificate No: **TAA00002UF**

Product description

Operating principles:

- KD-12 (H) = Horizontal, (V) = Vertical (p) = N on-flow magnetic switch
- KD-30 Float level reed switch, maximal 6 points
- KD-90 Displacement magnetic switch

Switch capacity:

- KD-12 250 VAC / 3A
- KD-30 250 VAC / 0,5 A
- KD-90 250 VAC / 15 A

Maximal working pressure:

- KD-12 7 bar
- KD-30 10 bar
- KD-90 10 bar

Maximal working temperature:

120 °C

Minimum specific gravity:

0,8 (see documentation for exact value)

Application/Limitation

Additional vibration damping measures might be necessary for long sizes

Type Approval documentation

[Korea Institute of Machinery and Metals \(KIMM\) IM3400250 \(14.12.1998\)](#)
[Temperature & Hydraulic pressure test report of KIMM \(04.05.2000\)](#)
[KD-12, KD-30 and KD-90 series drawings](#)
[Type approval assessment report for 1539000 HH dated 2020-06-18](#)

Tests carried out

Applicable tests according to Class Guideline DNVGL-CG-0339, December 2019

Marking of product

- Manufacturer name
- Model name
- Serial number

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE