



EUROPEAN UNION RECOGNISED ORGANISATION (EU RO) MUTUAL RECOGNITION TYPE APPROVAL CERTIFICATE

In accordance with Article 10.1 of EU Regulation 391/2009

Certificate No:
MRA000001R
Revision No:
3

This Certificate is issued to

PSM Instrumentation Ltd
Haywards Heath, West Sussex, United Kingdom

for

Pressure Gauges/Transmitters

with type designation(s)

**APT 500 / SPT 900 / APT 590 / SPT 990 Series analogue pressure and level transmitters,
APT 1000 / SPT 9000 Series analogue and digital pressure and level transmitters**

The product is found to comply with

EU RO Mutual Recognition Technical Requirements for Pressure Gauges – Transmitters

Intended service

**Pressure transmitters for use in control, alarm, monitoring and instrumentation systems subject to
classification, including ballast, cargo, and service tank gauging.**

Temperature [°C]: APT590 / SPT990: -40°C and 85°C, Others: -35°C and 90°C
Vibration: ±1 mm / 0.7 g
EMC: All locations including bridge and open deck
IP Code: Model Code ending with letter
S-submersible with cable: IP68 (50 m),
D-with DIN plug DIN EN 175 301-803 (DIN 43650): IP65

This is to certify:

that the Product referred to herein has been inspected for the Manufacturer, pursuant to the relevant requirements of the European Union Recognised Organisation Mutual Recognition procedure, required by Article 10.1 of EU Regulation 391/2009, and has been found in accordance with those requirements.

This Certificate is valid until **2029-04-09**.

Issued at **Høvik** on **2025-07-30**

DNV local unit: **UK & Ireland CMC & VMC**

for **DNV**

Approval Engineer: **Sonali Marathe**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.

Product description

Pressure and Level transmitter with measuring Range: 0.5 to 40 Bar and housing material: Titanium / Hastelloy / Stainless Steel.

Model Code: APT500, APT590, SPT900, SPT990
 - Transmitter output 4-20mA

Model Code: APT1000 & SPT9000
 - Transmitter output 4-20mA & Modbus protocol

Model Code ending with following letters:

S - submersible with cable - IP68

D - with DIN plug DIN EN 175301-803 (DIN 43650) - IP65

Fully submersible construction may be mounted internal or external to tank.

Firmware version: 1.0

Manufactured by

PSM Instrumentation Ltd,
 Unit 3, Burrell Road, Haywards Heath,
 West Sussex, RH16 1TW, United Kingdom

Application/Limitation

The pressure transmitter shall be powered by the 4-20 mA loop by an instrument power supply.

Ex-certification is not covered by this certificate. Application in hazardous area to be approved in each case according to the Rules and Ex-Certification/ Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body.

Type Approval documentation

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Other conditions

The pressure transmitters have been verified for compliance with EU Mutual Recognition Technical Requirements for Pressure gauges – transmitters version 0.3, dated 2024-07-01.

Environmental test parameters

Temperature: -35°C ~ +90°C

Vibration: ±1.0 mm / 0.7 g

Humidity: 95%RH @ 55°C, damp heat cyclic

EMC: All locations including bridge and open deck

Enclosure: IP65 – when delivered with DIN plug DIN EN 175301-803 (DIN 43650)

IP68 (50 m, 24 hours) – when delivered with cable (IP-ratings according to IEC 60529)

DNV location classes

D

A

B

B

B

D

The technical requirements do not specify any special design requirements for the cable. The vented gauge transmitters are delivered with an integrated special cable (Refer type approval documentation - Cable drawing) that has been reviewed and found to comply with DNV rules for classification of ships Pt.4 Ch.8 Sec.9.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)



Job Id: **262.4-000098-4**
Certificate No: **MRA000001R**
Revision No: **3**

- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment will be performed annually and at renewal of the certificate.

END OF CERTIFICATE

Generic Statement for EU RO MR Type Approval Certificate

When a product is presented with this EU RO MR Type Approval Certificate for given application, its acceptability with regards to the limitations stated in the certificate conditions defined in 1b, 1c and 1d of the applied Technical Requirement will be evaluated by the EU RO in charge of classing the ship or being in charge of the unit/system certification.

In accordance with Article 10 of Regulation (EC) No 391/2009 of the European Parliament and of the Council of 23 April 2009 "on common rules and standards for ship inspection and survey organizations", the following organizations, recognized by the EU on this date, have agreed on the technical and procedural conditions under which they will mutually recognize this certificate:

- American Bureau of Shipping (ABS);
- Bureau Veritas (BV);
- China Classification Society (CCS);
- Croatian Register of Shipping (CRS);
- DNV;
- Indian Register of Shipping (IRS);
- Korean Register (KR);
- Lloyd's Register Group Ltd. (LR);
- Nippon Kaiji Kyokai General Incorporated Foundation (ClassNK);
- Polish Register of Shipping (PRS);
- RINA Services S.p.A. (RINA).

The scheme for the mutual recognition of class certificates for materials, equipment and components laid down by Article 10(1) of Regulation (EC) No 391/2009 is only enforceable within the Union in respect of ships flying the flag of a Member State. As far as foreign vessels are concerned, the acceptance of relevant certificates remains at the discretion of relevant non-EU flag States in the exercise of their exclusive jurisdiction, notably under the United Nations Convention on the Law of the Sea (UNCLOS). (In accordance with COMMISSION IMPLEMENTING REGULATION (EU) No 1355/2014 amending Regulation (EC) No 391/2009 - recital (25)).